

Fire test reports LANDOLT products.

Fire testing standards for products in the building and construction sector

	Standard	Application	test according to	classification	test institute	production
Contraphon FR S 170	EN 13501-1	Building products	DIN EN ISO 11925-2 DIN EN 13823	B - s1,d0	MPA Dresden http://www.mpa-dresden.de	8752 Näfels - CH
Floorliner FR	EN 13501-1	Building products Floor protection	DIN EN ISO 11925-2 DIN EN ISO 9239-1	Bfl - s1	MPA Dresden http://www.mpa-dresden.de	8752 Näfels - CH

Fire testing standards for products in the transport sector (Maritime - IMO)

	Standard	Application	classification	notified body	production
Floorliner FR	IMO Res. MSC.307(88) - 2010 FTP Code, Annex 1, Part 5	floor coverings	passed	DNV GL www.gnvgl.com	8752 Näfels - CH